

**SPILL PRIORITY LIST - Effective April 1, 2015, until further notice.**

Priority Order	Project	TDG Cap (%)	Example Spill Caps (kcfs)
<b>LEVEL 1: State TDG Standard <sup>a</sup></b>			
1	LWG	120% / 115%	41
2	LGS	120% / 115%	40
3	LMN (bulk)	120% / 115%	28
4	LMN (uniform)	120% / 115%	36
5	IHR	120% / 115%	95 Night / 75 Day
6	MCN	120% / 115%	146
7	JDA	120% / 115%	90
8	TDA	120% / 115%	135
9	BON	120% *	130
10	CHJ	110%	20
11	GCL <sup>b</sup>	110%	OT=0; DG=5
12	DWR	110%	30%
<b>LEVEL 2</b>			
13	LWG	120%	45
14	LGS	120%	52
15	LMN (uniform)	120%	44
16	IHR	120%	95 Night / 75 Day
17	MCN	120%	146
18	JDA	120%	146
19	TDA	120%	135
20	CHJ	120% / 115% *	60
21	GCL <sup>b</sup>	115%	OT=5; DG=15
<b>LEVEL 3</b>			
22	LWG	122%	52
23	LGS	122%	59
24	LMN (uniform)	122%	60
25	IHR	122%	95 Night / 85 Day
26	MCN	122%	152
27	JDA	122%	177
28	TDA	122%	160
29	BON	122%	160
30	CHJ	120%	100
31	GCL <sup>b</sup>	120%	OT=15; DG=40
<b>LEVELS 4-7: same order as LEVEL 3</b>			

\* No downstream forebay standard.

\* Assumes spill duration ≤6 hrs.

<sup>a</sup> State waivers in effect Apr 1-Aug 31 at four Lower Columbia and four Lower Snake R. projects for TDG ≤120% in the tailrace (OR, WA) and ≤115% in next downstream forebay (WA), except BON which does not have a downstream forebay standard. Current 120%/115% spill caps available at: <http://www.nwd-wc.usace.army.mil/tmt/documents/ops/spill/caps/>

<sup>b</sup> GCL spill is via outlet tubes (OT) or drumgates (DG). Transition to DG at forebay elevation 1267-1270 ft.