

LGS Special Spill Operations for Adult Passage

(updated Wednesday 6/14/17, 10am)

Coordinated at TMT Fri, June 2.

Implemented Sat, June 3 – Mon, June 5 (3 days):

4 am – 10 am (6 hours):

- Spill maintained at 40% of total project outflow.
- Five available turbine units operated as constant as possible.

10 am – 4 pm (6 hours):

- Spill increased to pass inflow (inflow = outflow).

4 pm – 4 am (12 hours):

- Spill increased to draft back to MOP range 633-634 ft.

---

Coordinated at TMT Mon, June 5.

Implemented Tues, June 6 – Wed, June 7 (2 days):

Red text indicates change from previous operation.

4am – 10am (6 hours):

- Spill maintained at 30% of total project outflow.
- Five available turbine units operated as constant as possible.

10am – 4pm (6 hours):

- Spill increased to pass inflow (inflow = outflow).

4pm – 4am (12 hours):

- Spill increased to draft back to MOP range 633-634 ft, if possible. Spill will **not** exceed 140 kcfs as a hard constraint to avoid exceeding 130% TDG in the LGS tailrace.

---

Coordinated at TMT Wed, June 7.

Implemented Thurs, June 8 through Wed, June 14 (7 days):

4am – NOON (8 hours):

- Spill maintained at 30% of total project outflow.
- Five available turbine units operated as constant as possible.

NOON – 4pm (4 hours):

- Spill increased to pass inflow (inflow = outflow).

4pm – 4am (12 hours):

- Spill increased to draft back to MOP range 633-634 ft, if possible. Spill will **not** exceed 140 kcfs as a hard constraint to avoid exceeding 130% TDG in the LGS tailrace.

**LGS Special Spill Operations for Adult Passage**

(updated Wednesday 6/14/17, 10am)

Date	Operation (red = change)	CHN Adults	CHN Jacks		Total Outflow (kcf)	Spill (kcf)	% Spill	% TDG	Forebay (ft)	Unit Outages for Screen Cleaning
Sat, Jun 3	40% 4am-10am	793	511	Min	134.6	54.6	39.5%	120.3%	633.0	none
				Max	192.0	109.7	57.3%	129.4%	634.7	
				24-hr Average	169.1	84.1	49.0%	125.6%	633.9	
Sun, Jun 4	40% 4am-10am	578	407	Min	132.3	52.7	39.6%	119.9%	633.0	none
				Max	190.9	108.9	57.0%	128.5%	634.5	
				24-hr Average	165.2	80.5	48.0%	124.8%	633.7	
Mon, Jun 5	40% 4am-10am	390	356	Min	132.8	52.9	39.6%	119.8%	633.2	U6 10am-noon; U4 1pm-4pm; U3 3pm-5pm
				Max	197.9	138.2	71.8%	129.0%	634.6	
				24-hr Average	168.1	91.0	53.2%	125.5%	634.0	
Tue, Jun 6	30% 4am-10am	1,542	334	Min	128.0	38.9	29.9%	117.4%	633.3	U3 10am-noon; U2 10am-3pm; U1 noon-4pm. EMERG DEBRIS SPILL 3pm-4pm
				Max	185.4	112.7	81.0%	143.8%	635.2	
				24-hr Average	161.0	85.8	52.2%	126.0%	634.3	
Wed, Jun 7	30% 4am-10am	1,384	260	Min	128.3	38.7	29.9%	117.8%	633.2	none
				Max	174.9	92.4	52.8%	126.8%	634.4	
				24-hr Average	149.7	64.1	42.1%	122.6%	633.8	
Thu, Jun 8	30% 4am-noon	1,398	362	Min	128.2	38.6	29.8%	117.5%	633.2	none
				Max	176.7	95.8	54.2%	127.0%	634.7	
				24-hr Average	150.8	65.0	42.0%	122.3%	633.9	
Fri, Jun 9	30% 4am-noon	948	265	Min	128.1	38.8	30.0%	116.7%	633.2	none
				Max	173.2	92.5	53.8%	127.3%	634.9	
				24-hr Average	150.5	64.7	41.9%	122.1%	634.2	
Sat, Jun 10	30% 4am-noon	1,338	347	Min	128.0	38.6	29.9%	116.7%	633.1	none
				Max	170.4	90.3	53.0%	126.7%	634.4	
				24-hr Average	147.0	61.8	41.2%	121.5%	633.7	
Sun, Jun 11	30% 4am-noon	1,520	376	Min	128.4	38.5	30.0%	116.7%	633.1	none
				Max	138.8	58.3	42.2%	120.7%	633.6	
				24-hr Average	132.7	46.9	35.2%	118.6%	633.4	
Mon, Jun 12	30% 4am-noon	1,242	322	Min	110.0	35.0	29.8%	115.9%	633.0	none
				Max	132.6	50.5	38.1%	119.6%	633.5	
				24-hr Average	120.9	38.6	31.9%	116.9%	633.3	

**LGS Special Spill Operations for Adult Passage**

(updated Wednesday 6/14/17, 10am)

Date	Operation <i>(red = change)</i>	CHN Adults	CHN Jacks		Total Outflow (kcf)	Spill (kcf)	% Spill	% TDG	Forebay (ft)	Unit Outages for Screen Cleaning
Tue, Jun 13	30% 4am-noon	907	245	Min	76.8	23.2	30.1%	115.1%	633.3	U2, U3 10am-3pm
				Max	127.2	58.7	52.6%	120.7%	634.1	
				24-hr Average	111.7	40.1	35.7%	116.8%	633.7	
Wed, Jun 14	30% 4am-noon			Min						none
				Max						
				24-hr Average						