

Summary of Lower Granite Dam Operation Associated with Emergency Transmission Line Outage During TMT Meeting on June 6

1. Effective Wednesday, June 20, 1200 to 1800 hours.
 - a. Spill 50 kcfs.
 - b. Operate unit 5 for station service.
 - c. Store remaining inflow in the forebay above the appropriate Minimum Operating Pool (MOP) elevation.
2. After the operation is complete.
 - a. Resume 120/115% gas cap spill operation.
 - b. Draft LWG forebay back to the appropriate MOP elevation within a period of 2 days.