

CENWP-OD-B

17 August 2023

MEMORANDUM FOR THE RECORD

SUBJECT: 23BON081 MFR Unit 14 Forced Outage

At 0214 on Thursday 17 August, Unit 14 at Powerhouse 2 (PH2) was forced out of service (OOS) due to water in the turbine bearing. All priority units remain running (U11, 12, 17, and 18), but U16 was ran in U14's place for power generation.

U14 remains OOS at the time of writing this memo. Updates will be provided as they become available.

Update on 18 August –

An update on the U14 outage: U14 returned to service at 1521 on 17 AUG. The water has been removed from the turbine bearing, but no cause was found as of yet.

-Jeanette

Sincerely,
Bonneville Project Fisheries