

FPP Change Form

9/14/07

Change Request Number: 09BON002

Date:3/12/08

Proposed by: Bonneville Power Administration

Location of Change

BON 2.2.2.

JDA 2.2

Proposed Change:

The NMFS 2004 BiOp sets a minimum spill level of 50 kcfs for BON and 30% for JDA from April 10 through August 31.

Reason for Change:

Clarification of the Biological Opinion requirement. Is not intended to be applied year round.

Comments from others:

Record of Final Action:

Approved at April 2008 FPOM