

FPP Change Form

Change Request Number: 09BON009

Date: 12/4/08

Proposed by: NWP

Location of Change: BON- section 4.2.1.3. Turbines and Spillways.

Proposed Change:

Current language-

4.2.1.3. Turbines and Spillways.

b. Certain turbine and spillway discharges at the projects are secondarily used to attract adult fish to fishway entrances, to keep predator fish from accumulating near juvenile release sites, and to move juveniles downstream away from the project. During the fish passage season, do not take units F1, F2, 1, 2, 11, 17, and 18 out of service, when practicable.

c. When practicable, do not take any other Powerhouse Two units out of service during June 21 through September 15, to minimize Powerhouse One operation.

Proposed language-

4.2.1.3. Turbines and Spillways.

b. Certain turbine and spillway discharges at the projects are secondarily used to attract adult fish to fishway entrances, to keep predator fish from accumulating near juvenile release sites, and to move juveniles downstream away from the project. During the fish passage season, do not take units *F1, F2, 1, 3, 11, and 18 out of service, when practicable.*

c. When practicable, do not take any other Powerhouse Two units out of service during June 21 through September 15, to minimize Powerhouse One operation, *except during split flows operations..*

Reason for Change: Corrects PH1 unit priority

Comments from others:

Record of Final Action: Approved at January 2009 meeting.