

FPP Change Form

Change Request Number: 10BON008

Date: 14 January 2010

Proposed by: NWP

Location of Change: BON 5.2

Proposed Change: Remove the last sentence- “Powerhouse One units 1 through 6, 8, and 10 have different MW output requirements because they are minimum gap runner units and have a different MW versus discharge relationship.”

Reason for Change: All PH1 units are MGR units now.

Comments from others:

Record of Final Action: approved at Feb FPOM.