**Change Request Number: 11BON013** 

**Date:** December 15<sup>th</sup>, 2010 **Proposed by:** David Benner, FPC **Location of Change-** BON 5.3

**Current Language: 5.3.** To the extent technically feasible, turbines will be operated within +/-1% of best turbine efficiency from April 1 through October 31 (as specified in the BPA load shaping guidelines) to avoid excess daytime spill (during the time of year when the 75 kcfs spill cap applies), or to comply with other coordinated fish measures. However, during the rest of the year, the project will continue to operate units within the 1% turbine efficiency range, except as specifically requested by BPA to do otherwise as provided in **Appendix C**.

**5.3.** To the extent technically feasible, turbines will be operated within +/-1% of best turbine efficiency from April 1 through October 31 (as specified in the BPA load shaping guidelines) to avoid excess daytime spill (during the time of year when the 75 kcfs spill cap applies), or to comply with other coordinated fish measures. However, during the rest of the year, the project will continue to operate units within the 1% turbine efficiency range, except as specifically requested by BPA to do otherwise as provided in **Appendix C**.

**Proposed Change: 5.3.** To the extent technically feasible, <u>T</u>turbines will be operated within +/-1% of best turbine efficiency from April 1 through October 31 (as specified in the BPA load shaping guidelines) to avoid excess daytime spill (during the time of year when the 75 kefs spill cap applies), or to comply with other coordinated fish measures. However, during the rest of the year, the project will continue to operate units within the 1% turbine efficiency range, except as outlined specifically requested by BPA to do otherwise as provided in **Appendix C**.

**Reason for Change:** This section was confusing and seemed to imply that a unit operation other than  $\pm 1\%$  was allowable when the daytime spill cap is 75 Kcfs.

## **Comments from others:**

**BON Fisheries-** Consulted with Bon senior operator regarding attached change form. The language is good as long as the last sentence is changed (please see tracked change) and no modifications to Appendix C.

USFWS- support

Record of Final Action: approved at 21 January 2011 meeting.