

# FPP Change Form

**Change Request Number:** 09BON008

**Date:** 9/11/2008 and 12/5/2008

**Proposed by:** FPOM

**Location of Change:** Table BON-11

**Proposed Change:** Include a row for unit priority, by powerhouse, when splitting flows. Better explain the unit priority when splitting flows.

**Table BON-11. Turbine unit operating priorities, Bonneville Powerhouses One and Two.**

PERIOD	PRIORITY
Year-round; adult fish ladders are in service	11,18,15,12,17,14,13,16, 3,1,4,6,2,5,7,10,9,8
First Powerhouse Adult Fish Ladder out of service	11,18,15,12,17,14,13,16, 3,1,4,6,2,5,7,10,9,8
Second Powerhouse Adult Fish Ladder out of service	3,1,4,6,2,5,7,10,9,8 11,18,15,12,17,14,13,16
<i>Split flows unit priority (all units available)</i>	<i>3,1,11,18,15,12,17,14,13,16,4,6,2,5,7,10,9,8</i>
<i>PH1 unit priority</i>	<i>3,1,4,6,2,5,7,10,9,8</i>
<i>PH2 unit priority</i>	<i>11,18,15,12,17,14,13,16</i>

*5.1. Powerhouse priority is detailed in **Table BON-11**. When splitting flows, as directed in section 2.1.2, the top two available priority units for PH1 will be operated first followed by normal unit priority at PH2. If there is a need for more units, and all available units at PH2 are in operation, proceed with the normal unit priority for PH1.*

**Reason for Change:** This clearly lays out the priority for each powerhouse when flows are split.

**Comments from others:** need to better explain the unit priority during split flows.

**Record of Final Action:** Approved at January 2009 meeting.