

**FPP Change Form**

**Change Request Number: 11BON004**

**Date:** 29 July 2010

**Proposed by:** BON Project Fisheries

**Location of Change:** BON Table-143.

**Proposed Change:** Turbine unit operating priorities, Bonneville Powerhouses One and Two.

| PERIOD   | PRIORITY  |
|--|---|
| Year-round; adult fish ladders are in service      | 11,18,15,12,17,14,13,16,1, <u>10</u> ,3,6,2,4,5,8, <u>10</u> ,7,9                           |
| First Powerhouse Adult Fish Ladder out of service  | 11,18,15,12,17,14,13,16,<br>1, <u>10</u> ,3,6,2,4,5,8, <u>10</u> ,7,9                       |
| Second Powerhouse Adult Fish Ladder out of service | 1, <u>10</u> ,3,6,2,4,5,8, <u>10</u> ,7,9<br>11,18,15,12,17,14,13,16                        |
| Split flows unit priority (all units available)    | 1, <u>10</u> <del>3</del> ,11,18,15,12,17,14,13,16, <u>3</u> ,<br>6,2,4,5,8, <u>10</u> ,7,9 |
| PH1 unit priority                                  | 1, <u>10</u> ,3,6,2,4,5,8, <u>10</u> ,7,9   |
| PH2 unit priority                                  | 11,18,15,12,17,14,13,16   |

**Reason for Change:** Unit 10 was a former priority unit. It would provide flushing flows along the north powerhouse shoreline. It is a unit with an automatic chain gate as well.

**Comments from others:** Lorz will spend time thinking about PH2 priority. Fredricks says moving U10 is ok.

**Record of Final Action:** Approved at August 2010 FPOM.