

FPP Change Form

Change Request Number: 10BON004

Date: 29 October 2009

Proposed by: FPOM

Location of Change: BON 5.8

Proposed Change: add the following language

| During high head events (such as a higher than normal forebay) the top ~~two~~ priority units at Powerhouse One may be operated, when necessary, to keep Powerhouse Two units within the 1% efficiency range.

Reason for Change: This is to address the issue with trying to maintain the 1% criteria when using only PH2 units during high head events. At least one PH1 unit needs to be operated to allow enough flexibility for units to operate within the 1% band without pushing against the upper or lower limits.

Comments from others: FPOM recommended only one unit at PH1 being operated.

Record of Final Action: Approved at November FPOM.