

FPP Change Form**Change Request Number:** 10JDA002**Date:** 06 October 2009**Proposed by:** JDA Fisheries**Location of Change:** JDA 4.2.2.3 Turbines and Spillways**Proposed Change:** Add 4.2.2.3.c from 15 September through 28

February, spill gate 2 may be closed for one work day, or less, for maintenance activities. During the outage, spill gate 3 will be opened to provide attraction flow.

Reason for Change: Reduces the need for coordination for brief and routine maintenance outside spill season. Spill gate 3 will provide attraction flow to compensate when spill gate 2 is closed.

Comments from others: This was discussed at the 06 October FPOM. 15 September was discussed and approved as the earliest date the spill gate could be closed for maintenance activities.

Record of Final Action: Approved at November FPOM.