

FPP Change Form

9/14/07

Change Request Number: 09JDA002

Date: 4/24/08

Proposed by: John Day Project

Location of Change- JDA 5

Proposed Change: Remove the requirement to run U5 as the first priority unit.

Table JDA-5. Turbine unit operating priority for John Day Dam.

Season	Time of Day	Unit Operating Priority
March 1 through November	24 hours/day	1, 2-5 in any order then 6-16 in any order.
December 1 through February	0600-2000 hrs	unpaired units in any order
	2000-0600 hrs	any unit

Reason for Change: The Project does not need U5 for station service. They would like the flexibility to run other units instead. Egress conditions are not dependant on U5 being the first unit on, but rather egress is dependent on the operation of any of turbine units 1-5.

Comments from others: include "in any order" after 1-5.

Record of Final Action: FPOM reviewed and agreed to the change at January 2009 meeting.