

# FPP Change Form

9/14/07

**Change Request Number:** 09JDA002-a

**Date:** 4/24/08, 2/12/2009

**Proposed by:** John Day Project

## Location of Change- JDA 5

**Proposed Change:** Remove the requirement to run U5 as the first priority unit.

**Table JDA-5. Turbine unit operating priority for John Day Dam.**

Season	Time of Day	Unit Operating Priority
March 1 through November	24 hours/day	1- <del>4</del> , <del>2-5</del> in any order then <del>5</del> 6-16 in any order.
December 1 through February	<del>0600-2000 hrs</del>	<del>unpaired units in any order</del>
	<del>24 hours/day</del> 2000- <del>0600 hrs</del>	any unit

**Reason for Change:** The Project does not need U5 for station service. They would like the flexibility to run other units instead. Egress conditions are not dependant on U5 being the first unit on, but rather egress is dependent on the operation of any of turbine units 1-5.

Unit 5 should not even be on the "fisheries" priority list. Unit 5 is the "projects" #1 priority unit for the simple fact that it feeds station service power. It has nothing to do with fish.

**Comments from others:** include "in any order" after 1-5.

NOAA- agree

**Record of Final Action:** FPOM reviewed and agreed to the change at January 2009 meeting. Recent changes not yet approved.

Changes approved and included in the FPP.