

**Change Request Number: 11TDA008**

**Date: 11/2/10**

**Proposed by: TDA Fisheries**

**Location of Change: 4.2.1.2.**

**Proposed Change: 4.2.1.2. Turbines and Spillways.** Maintenance and routine repair of project turbines and spillways are a regular and recurring process which require that units be shut down for extended periods (see section **6. Dewatering Plans.**) ... Units which should receive low priority for scheduling maintenance during the fish passage season are F1, F2, 1, 2, 3, 4 ~~5~~8, and 18 (during ice and trash sluiceway operation).

**Reason for Change:** Unit 8 now has the operating sluiceway and should be a higher priority than unit 5.

**Comments from others:**

NOAA Fisheries- Agree with these changes.

USFWS- support

**Record of Final Action: approved 21 January 2011 meeting.**