

**CENWP-OD-B**

**30 June 2023**

**MEMORANDUM FOR THE RECORD**

**SUBJECT: 23BON041 MFR Unit 18 Outage**

U18 showed exciter trouble alarms and was forced OOS at 1405 on 29 June. After a thorough assessment, no cause was found for the trip and the unit was RTS at 1618 the same day. U17 was ran in its place during the outage.

Sincerely,  
Project Fisheries