

CENWP-ODJ

5/1/2023

MEMORANDUM FOR THE RECORD

SUBJECT: *23JDA13 spill gate #12 out of service due to brake failure*

On Saturday 29 April 2023, at approximately 1649, Spill Gate #12 closed and was taken out of service due to a brake failure.

Crews are working to correct the issue. However, currently the return to service date is undetermined. The gate will be dogged off at 2 opening and will be adjusted manually with operations staff as patterns change.

Sincerely,
JDA Project Fisheries