

CENWP-ODJ

5/4/2023

MEMORANDUM FOR THE RECORD

SUBJECT: *23JDA15 spill gate #6 operated in manual*

On Wednesday 3 May 2023, at approximately 1427, Spill Gate #6 would not respond to auto controls from the control room and was put into manual mode.

Crews are working to correct the issue. However, currently the return to service date is undetermined. The gate will be adjusted manually with operations staff as patterns change.

Sincerely,
JDA Project Fisheries