

MEMORANDUM FOR THE RECORD

SUBJECT: 24JDA07 5A Orifice Valve Air Leak

On 7 June 2024, at 0728, JDF main unit 5 was forced out of service due to an air leak in the line supplying the orifice valve for 5A. JDM repaired the air line and the unit was returned to service at 1338 the same day.

- A. Species – NA
- B. Origin – NA
- C. Length – NA
- D. Marks and tags – NA
- E. Marks and Injuries found on carcass –NA
- F. Cause and Time of Death – NA
- G. Future and Preventative Measures- Daily gateway inspections.

Sincerely,

Project Fisheries