

CENWP-OD-*The Dalles Dam*

08/16/2023

MEMORANDUM FOR THE RECORD (*23TDA12 unit priority restriction*)

SUBJECT: *Turbine unit priority operation restriction*

On Aug 14 and 15, Turbine unit priority operation per Fish Passage Plan requirements could not be met due to BPA line 3 shutdown from excessive heat. This required main units 5 through 8 to be off line during the restriction for several hours each day

Sincerely,
TDA Project Fisheries