

CENWW-ODL

November 28, 2023

MEMORANDUM FOR THE RECORD: 23 LWG 11 AWS Pumps Out of Service

SUBJECT: All AWS pumps were removed from service for DC ground testing.

LWG AWS pumps were removed from service to test DC grounds in the AWS control panel. Troubleshooting continues to identify the cause of recent AWS pumps tripping offline. All AWS pumps were offline from 1209-1216 hours November 28. AWS pump 1 and 2 were returned to service and AWS pump 3 will remain in standby.

- A. Species – N/A
- B. Origin – N/A
- C. Length – N/A
- D. Marks and tags – N/A
- E. Marks and Injuries found on carcass – N/A
- F. Cause and Time of Death – N/A
- G. Future and Preventative Measures – N/A

Sincerely,

David Miller
Supervisory Fisheries Biologist
Lower Granite Project and Dworshak Dam
Walla Walla District
Ph. (509) 843-2264