

## MEMORANDUM FOR Biologist, Operations Division (CENWP-OD)

SUBJECT: Bonneville Project, Fishway and Fish Activities for Week 07 of 2016, which covers the period from 07 to 13 February 2016.

**1. OPERATION SUMMARY:**

a. Daily average river flows ranged from 125 to 181 kcfs. Daily average powerhouse forebay elevation ranged from 73.7' to 75' msl. Daily average project tailwater ranged from 12.5' to 16.3' msl. Secchi disk measurements stayed at 7.0'. Daily average water temperature was 42 °F.

b. Spill bay 1 is open 0.5' during daytime hours to provide attraction flow to the Cascades Island fish ladder. Daily average spill was 0.5 kcfs.

(1) Spill bay 18 was closed at 1830 on 04 December for the Bradford Island (B-Branch) winter maintenance dewatering.

c. Unit Operation. Powerhouse two remains the priority powerhouse. Main unit draw downs are measured every Monday and more frequently as needed.

(1) Table 1. Unit Outages.

Unit	OOS Date	RTS Date	Reason
9	1053 on 17 Nov	1335 on 11 Feb	5 year overhaul, bank 9/10 maint
10	1015 on 16 Nov	1643 on 09 Feb	Annual maintenance and air gap
F2	0001 on 15 Dec	---	2 year overhaul
1	0803 on 10 Feb	1040 on 10 Feb	Planned Outage, Rake Trash
2	1040 on 10 Feb	1328 on 10 Feb	Planned Outage, Rake Trash
3	1325 on 10 Feb	1626 on 10 Feb	Planned Outage, Rake Trash
4	0722 on 11 Feb	0859 on 11 Feb	Planned Outage, Rake Trash
5	0900 on 11 Feb	1133 on 11 Feb	Planned Outage, Rake Trash
6	1300 on 11 Feb	1640 on 11 Feb	Planned Outage, Rake Trash

d. Fish Units. Second Powerhouse fish units provide attraction flow for the Washington Shore (WS) fish ladder.

(1) F2 was taken out of service for a 2 year overhaul at 0001 on 15 Dec. At 0707 Powerhouse 2 went to single fish unit ops, and the NUE gate was closed.

(2) The fish units were placed on standby to float trash, or to allow trash to be raked on units 17 and 18 without causing debris to be pulled to the fish units, during the following times:

F1: -

F2: N/A

(3) Table 2. Fish unit drawdowns, in feet.

Date	F1	F2
02/07	0.6'	--
02/08	0.9'	--
02/09	0.8'	--
02/10	0.8'	--
02/11	1.0'	--
02/12	1.0'	--
02/13	1.2'	--

## 2. ACTIVITIES:

- a. Auxiliary Water System Closures  
None.
- b. STS/VBS inspections  
All STS/VBS are removed.
- c. Dewatering and Fish Salvages  
None.

## 3. RESEARCH:

- a. Normandeau – Fish Counting  
Visual counting ended and video counting began on 01 December.

## 4. FISHWAYS:

- a. Project biologists inspected 08, 09 and 11 February.
- b. Fish passage plan observations.

(1) Table 3. FPP out of criteria items.

Date	Location	FPP Items	Cause	Response
<b>BRADFORD ISLAND – Dewatered.</b>				
<b>CASCADES ISLAND</b>				
<b>WASHINGTON SHORE</b>				
2/9	Weir 37, 38	Water level <.9'	unknown	none

- (2) WG-1, one of the south PH1CC entrances, experienced a gate failure on 17 November 2014. Divers recovered the gate's picking beam on 04 August 2015. Repairs are ongoing. The gate is estimated to return to service during the 2015/16 winter maintenance.
- (3) A-branch diffuser FG3-3 is mechanically bound. Repairs are not possible until A-branch is dewatered below tailwater during the 2015/16 winter maintenance period.
- (4) PH2CC diffuser A2 was unable to be repaired during winter maintenance 2014/15 and remains closed. It should be open when tailwater is above 13.0 msl. The gate for diffuser B5 was removed for repairs and therefore cannot be closed. It should be closed below tailwaters of 12.0 msl.

c. Fishway Temperatures. Temperatures are taken from 01 March through 30 November. Forebay temperatures can be found [online](#).

d. Zebra Mussel Monitoring. No signs of colonization were observed this reporting week.

e. Avian Monitoring. Bird counts are made between 01 April and 31 October.

f. Adult Fishways.

- (1) Fishway instrument calibration was checked on 11 February.
- (2) 11 of 12 floating orifice gates (FOGs) are installed; one gate is out for maintenance. FOG Stab plates are installed. Powerhouse 2 adult fishway is currently configured for a single fish unit operation in accordance with Table BON 12 in the FPP.
- (3) SLEDs were installed in the PH2 entrances on 26 October 2015. The PH1 SLEDs are removed.
- (4) 8 SLIBs (Sea Lion Incursion Barriers) were installed on top of FOGs to prevent Sea Lions from jumping into the PH2 fishway on 11 February.

g. Juvenile Fishways.

- (1) The ITS remains open.
- (2) The hydro-cannon remains off.
- (3) The B2CC was opened to flush debris from 0730 to 0927 on 10 Feb.
- (4) The DSM remains in service.

h. Lamprey Fishways.

- (1) All LPSs remain out of service.

**5. CONSTRUCTION:** Nothing to report.

**6. HAZMAT, SPILLS AND CLEANUP:** Nothing to report.

**7. TELETYPES CURRENTLY IN EFFECT:**

a. A teletype sent on 30 March updates the spill caps and lack of load conditions to be used from 0000 on 01 April until further notice.

b. A teletype sent on 06 January updated previous Chum tailwater operations. Effective immediately until further notice operate BON tailwater at a minimum of 12.5' for all hours. This operation is to protect Chum Redds below BON at the Ives/Pierce Island complex.

c. A teletype sent on 29 January states that all 18 spillbays at Bonneville Dam will be out of service from 0600 to 1700 daily from 17 February through 25 February. These daily outages facilitate inspection of the gates.

d. A teletype sent on 01 February updates one sent on 29 January (c. above) and states that spillbay 1 will remain open one stop for attraction flow during the 17-25 February window.

JERRY A. CARROLL  
Operations Manager  
Bonneville Project