CENWP-OD-B 06 June 2016

MEMORANDUM FOR Biologist, Operations Division (CENWP-OD)

SUBJECT: Bonneville Project, Fishway and Fish Activities for <u>Week 23</u> of 2016, which covers the period from <u>29 May to 04 June.</u>

1. OPERATION SUMMARY:

- a. Daily average river flows ranged from 194.5 to 224.4 kcfs. Daily average powerhouse forebay elevation ranged from 73.5 to 74.6' msl. Daily average project tailwater ranged from 16.8 to 18.1' msl. Secchi disk measurements ranged from 5 to 7'. Daily average water temperature ranged from 59 to 61°F this week.
- b. Spring spill began on 10 April. Daily average spill ranged from 98.9 to 100.7 kcfs.
- c. Unit Operation. PH2 remains the priority powerhouse. Main unit draw downs are measured every Monday and more frequently as needed.

(1) Table 1. Unit Outages.

	,		
Unit	OOS Date	RTS Date	Reason
5	0000 on 14 Apr	1538 on 01 June	Cubicle measurements, 230 kV
6	0000 on 14 Apr	1538 on 01 June	disconnect broken
5	1732 on 03 June		MUB install
6	1732 on 03 June		MUB install
7	0103 on 22 Feb		Annual, bank 7/8 outage, main unit
8	0103 on 22 Feb		breaker replacement, raking trash
11	0729 on 31 May	0832 on 31 May	Rake Trash
11	0955 on 01 Jun	1352 on 01 June	Rake Trash

d. Fish Units. Second Powerhouse fish units provide attraction flow for the Washington Shore (WS) fish ladder.

(1) Table 2. Fish unit drawdowns, in feet.

Date	F1	F2
5/29	0.5	0.4
5/30	0.5	0.4
5/31	0.3	0.2
6/1	0.3	0.2
6/2	0.4	0.4
6/3	1.4	1.1
6/4	0.3	0.3

2. MAINTENANCE ACTIVITIES:

- a. Auxiliary Water System Closures. None.
- b. STS/VBS inspections. None.
- c. <u>Dewatering and Fish Salvages.</u> None.

3. RESEARCH:

- a. CRITFC AFF. Adult sampling in the AFF continues.
- b. <u>Fisheries Field Unit Pinniped observation</u>. Observations concluded 27 May.
- c. NOAA Sort by code. Sampling as part of a NWW transportation study began the week of 24 April.
- d. Normandeau Fish counting. Visual counting continues.
- e. <u>PSMFC Smolt Monitoring Program</u>. SbyC is active for NOAA, 26 clipped juvenile salmonids were collected for UW/NOAA. No fish were examined for GBT due to insufficient fish numbers. Fallbacks recorded crossing the separator bars: 9 steelhead, 3 salmon, and 4 unknown salmonids. More details can be found on the <u>FPC web page</u>.
- f. <u>USDA Avian and pinniped hazing.</u> Dam-based hazing for pinnipeds concluded 31 May, birds hazing occurs 1 April 31 July.
- g. <u>USFWS Fish Health Center</u>. Sort by code collection of juvenile hatchery fish began the week of 09 April.
- h. <u>UW/NOAA Fish condition</u>. Juvenile sampling at the SMF for a study of SAR and differential delayed mortality began 27 April.

4. FISHWAYS:

- a. Project biologists inspected 29 May 04 June.
- b. Fish passage plan observations.
 - (1) Table 3. FPP out of criteria items.

Date	Location	Location FPP Items Cause		Response	
BRADFORD ISLAND					
5/27	A-branch	Water over weir > 1.1'	FV3-7 conduit leak	Repair in 2017	

CASCADES ISLAND – Nothing to report						
WASHINGTON SHORE						
5/31,6/2 Weir 37 Water over weir > 1.1' Unknown Ops manua						
ongoing	PH2	Diffuser A2 closed	See 4.b.2 below	None		

(2) PH2CC diffuser A2 was unable to be repaired during winter maintenance 2014/15 and remains closed. It should be open when tailwater is above 13.0' msl. The gate for diffuser B5 was removed for repairs and therefore cannot be closed. It should be closed when tailwater is below 12.0' msl or above 28.0' msl.

c. Adult Fishways.

- (1) The WA shore ladder went to shad mode on 01 June, the Bradford ladder on 02 June. (Changes water levels over ladder weirs from 1.0 to 1.3 ft.)
- (2) The AFF remains in service.
- (3) Fishway instrument calibration was checked on 01 June.
- (4) Eight of 12 floating orifice gates (FOGs) are installed; the 4 middle slots have bulkheads in place. FOG sea lion bars are installed. Plywood sea lion barriers were installed on top of all FOGs on 11 February to prevent sea lions from jumping into the PH2CC.
- (5) All SLEDs are installed.

d. Juvenile Fishways.

- (1) The ITS remains in service.
- (2) The hydro-cannon is on.
- (3) The B2CC remains in service.
- (4) The DSM remains in service.

e. Lamprey Fishways.

- (1) The Bradford Island LPS, WA AWS LPS, and the Cascade Island LPS remain in service.
- (2) Due to needed repairs, the NDE LFS/LPS will remain out of service for the 2016 season. Repairs are currently being coordinated for November 2016.
- f. Avian Monitoring. Bird counts are made between 01 April and 31 October.

(1) Table 5. Counts of tailrace foraging piscivorous birds.

Date	Gulls	Cormorants	Terns	Wh. Pelicans	Grebes
5/29	1	3	0	0	0
5/30	0	1	0	0	0
5/31	0	0	0	0	0
6/1	0	8	0	0	0
6/2	0	1	0	0	0
6/3	0	0	0	0	0
6/4	2	0	0	0	0


5. WATER QUALITY MONITORING:

a. <u>Fishway Temperatures.</u> Temperatures are taken from 01 March through 30 November. Forebay temperatures can be found <u>online</u>.

(1) Table 4. Average daily fishway water temperatures (Fahrenheit).

(1) Table 1: 7 Verage daily heriway water temperatures (1 amenhety:								
		Fishways			Lamprey			
Date	Forebay	Brad. Is.	WA shore	AFF	SMF	BI LPS	WA LPS	CILPS
5/29	59.0	58.6	58.1	58.2	59.2	59.4	57.7	58.4
5/30	59.4	58.9	58.6	58.7	59.6	59.9	58.2	58.9
5/31	60.1	59.5	59.2	59.3	60.2	60.6	58.8	59.6
6/1	60.6	60.1	59.7	59.8	60.7	61.2	59.3	60.1
6/2	60.9	60.4	60.1	60.1	61.1	61.2	59.6	60.3
6/3	61.5	61.0	60.7	60.8	61.6	62.1	60.3	61.1
6/4	62.1	61.6	61.2	61.3	62.2	63.0	60.9	62.0

(2) Figure 1. Graph of fishway water temperatures (Fahrenheit).



b. <u>Zebra Mussel Monitoring</u>. No signs of colonization were observed this reporting week.

- **6. CONSTRUCTION:** Nothing to report.
- 7. HAZMAT, SPILLS AND CLEANUP: Nothing to report.

8. TELETYPES CURRENTLY IN EFFECT:

- a. A teletype sent on 23 April updates the spill caps and lack of load conditions to be used from 0000 on 1 April until further notice.
- b. A teletype sent on 7 April states effective 10 April to 31 August, provide spring and summer spill per the 2015 Fish Operations Plan. A schedule and specific operations are provided. The B2CC will operate concurrent with spill.
- c. A teletype sent on 31 May cancels the Columbia River Flood Risk Management (FRM) effective 0001 on 01 June.
- d. A teletype sent on 3 June requests that BPA make best efforts to maintain BON pool at the current level of 74.0 msl until further notice due to a train derailment at Mosier, OR.
- e. A teletype sent on 3 June cancels the previous teletype due to no oil entering the river. If the situation changes a new teletype will be issued.

JERRY A. CARROLL Operations Manager Bonneville Project