

**U.S. ARMY CORPS OF ENGINEERS
WALLA WALLA DISTRICT
FISH FACILITIES WEEKLY REPORT
#02-2020**

Project: McNary

Biologist: Bobby Johnson and Denise Griffith

Dates: March 6 to 12, 2020

Turbine Operation

| Yes | No | Turbine Unit Status | Hard | Soft |
|-----|----|---|------|------|
| | X | All 14 turbine units available for service. (See table & comments below for details). | | |
| | X | Available turbines operated within 1% peak efficiency? Constraint in effect. | | X |

Table 1. McNary Unit Outages (OOS) and Return to Service (RTS).

| Unit | OOS | | RTS | | Outage Description |
|------|---------|------|--------|------|------------------------|
| | Date | Time | Date | Time | |
| 5 | 5/23/19 | 0943 | 4/7/20 | NA | Turbine blade packing. |

Comments: The soft one percent peak efficiency constraint continued. At times, units can run outside the constraint at BPA's request. The hard constraint will begin April 1.

Adult Fish Passage Facilities

McNary fisheries biologists performed measured inspections of the adult fishways on March 6, 8 and 11. Adult fish counting will resume April 1, at which time the picketed leads will be lowered.

Fish Ladder Exits:

| Yes | No | Location | Criteria | Comments |
|-----|----|---------------------------------------|-----------------------------|----------|
| X | | Oregon Exit | Head over weir 1.0' to 1.3' | |
| X | | Oregon Count Station Differential | 0.0' to 0.5' | |
| X | | Washington Exit | Head over weir 1.0' to 1.3' | |
| X | | Washington Count Station Differential | 0.0' to 0.5' | |

Comments: Debris loads were minimal near both exits. Tumbleweeds have been observed on and removed from the Washington ladder trash rack.

At the Washington exit, one regulating weir alarm came in and was reset on March 6. A brief power outage to test the backup spillway diesel system had not adverse effect at the exit on March 10.

Fishway Entrances and Collection Channel:

| Yes | No | Sill | Location | Criteria | Comments |
|-----|----|------|---|----------------|-------------------|
| X | | | North Oregon Entrance Head Differential | 1.0' – 2.0' | |
| | X | | NFEW2 Weir Depth | ≥ 8.0' | 7.9' on March 6. |
| | X | | NFEW3 Weir Depth | ≥ 8.0' | 7.9' on March 6. |
| X | | | South Oregon Entrance Head Differential | 1.0' – 2.0' | |
| X | | | SFEW1 Weir Depth | ≥ 8.0' | |
| X | | | SFEW2 Weir Depth | ≥ 8.0' | |
| X | | | Oregon Collection Channel Velocities | 1.5 to 4.0 fps | Averaged 1.7 fps. |
| X | | | Washington Entrance Head Differential | 1.0' – 2.0' | |
| X | | | WFE2 Weir Depth | ≥ 8.0' | |
| X | | | WFE3 Weir Depth | ≥ 8.0' | |

Comments: For the north powerhouse entrances, the out of criteria points listed above may have been due to calibration drifts.

Auxiliary Water Supply System:

| Operating Satisfactory | Standby | Out of Service | Auxiliary Water Supply System (AWS) |
|------------------------|---------|----------------|---|
| Yes | | | WA shore Wasco County PUD Turbine Unit |
| | Yes | | WA shore Wasco PUD Bypass |
| | | Yes | Oregon shore Fish Pump 1, OOS to September 12. |
| Yes | | | Oregon Ladder Fish Pump 2, Blade angle: 23 degrees |
| Yes | | | Oregon Ladder Fish Pump 3, Blade angle: 26 degrees |
| Yes | | | OR North Powerhouse Pool supply from juvenile fishway |

Comments: There are no problems to report.

Juvenile Fish Passage Facility

The sampling season, consisting of alternating days of primary and secondary bypass, continued. There were no interruptions in the schedule. Sampling on March 8 was concluded at 0800 hours in order to insure a 24 hours sample was collected after daylight savings time had begun.

Forebay Debris/Gatewell Debris/Oil:

| Yes | No | NA | Item | Comments |
|-----|----|----|--|-------------------------------|
| X | | | Forebay debris load acceptable? (amount) | Heavy. New debris is minimal. |
| X | | | Trash rack differentials measured this week? | Daily. |
| X | | | Trash rack differentials acceptable | |
| | X | | Any debris seen in gatewells (% coverage) | |
| | X | | Any oil seen in gatewells? | |

Comments: The only debris, which would be described as heavy, is at the powerhouse. New debris and debris near the spillway would be described as minimal. Debris removal will occur when the spill program begins in April.

The next trash rack cleaning is scheduled to start on March 23.

There are no problems to report.

Extended-length submersible bar screen (ESBSs)/Vertical barrier screen (VBSs):

| Yes | No | NA | Item |
|-----|----|----|---|
| | X | | ESBSs deployed in all slots and in service? |
| | X | | ESBSs inspected this week? |
| | | X | ESBSs inspection results acceptable? |
| X | | | VBSs differentials checked this week? |
| X | | | VBSs differentials acceptable? |

Comments: ESBS's are installed in units 1, 10, 13 and 14 for early startup sampling and for the adult steelhead top spillway weir (TSW) passage efficiency study. The installation of the remaining ESBS's will begin on April 2. There are no problems to report. Camera inspections in the four units mentioned above will begin in late March.

VBS differential monitoring continued. No high differentials were measured and no screens were cleaned.

Orifices, Collection Channel, Dewatering Structure, and Bypass Pipe:

| Yes | No | NA | Item | Number of orifices in service |
|-----|----|----|--|-------------------------------|
| X | | | Orifices operating satisfactory? | 42 |
| X | | | Dewaterer and cleaning systems operating satisfactory? | |

Comments: Orifice valve operators were repaired as required this week.

There are no problems.

Bypass Facility:

| Yes | No | NA | Item |
|-----|----|----|-----------------------------|
| X | | | Sample gates on? |
| | | X | PIT-tag sampling system on? |

Comments: The sample gates were only operated on secondary bypass days. The PIT-tag system remained out of service as there are no studies requiring its use.

This week, 3,532 juvenile lamprey and 104 smolts were bypassed during secondary bypass.

Area light was repaired or replaced at the facility this week.

TSW Operations: The TSW remained installed in bay 20 for the TSW passage study. The TSW was operated per the study plan.

River Conditions

Table 4. River Conditions at McNary Dam.

| Daily Average River Flow (kcfs) | | Daily Average Spill (kcfs) | | Water Temperature (°F) | | Water Clarity (Secchi disk - feet) | |
|---------------------------------|-------|----------------------------|-----|------------------------|------|------------------------------------|-----|
| High | Low | High | Low | High | Low | High | Low |
| 150.9 | 112.1 | 3.0 | 0.0 | 42.2 | 41.6 | 4.7 | 3.0 |

Comments: The above data was supplied by the smolt monitoring staff except water clarity, which came from the control room. All spill recorded was for the TSW passage study.

Other

Inline Cooling Water Strainers: The next cooling water strainer examinations are scheduled for April 7.

Avian Activity: Avian counts will begin on April 1. Gulls have been observed around the project in low numbers. Cormorants have been noted roosting on the outfall pipe and/or navigation lock wing wall in fairly high numbers. Feeding activity by both has been minimal. A few mergansers were also noted.

The first bird distress call was deployed on the outfall walkway on March 10. There appeared to be limited success.

Invasive Species: No Siberian prawns were observed in this week's samples. Mussel stations will be examined in late March.

Fish Rescue/Salvage: At the navigation lock, on March 9, the adult mortalities were two walleye, three shad and two suckers. All were highly decomposed. The juvenile mortalities were three smallmouth bass and three yellow perch. All were fresh. No other fish were recovered.

Research: The adult steelhead top spillway weir (TSW) passage efficiency continued. A brief power outage to test the backup spillway diesel system had no adverse effect with the study's systems on March 10.

Project: Ice Harbor

Biologist: Ken Fone

Dates: March 6 – March 12, 2020

Turbine Operation

| Yes | No | Turbine Unit Status | Hard | Soft |
|-----|----|---|------|------|
| | X | All 6 turbine units available for service (see table & comments below for details). | | |
| X | | Available turbines operated within 1% peak efficiency? Constraint in effect. | | X |

Ice Harbor Unit Outages (OOS) and Return to Service (RTS)

| Unit | OOS | | RTS | | Outage Description |
|------|--------|------|------|------|--|
| | Date | Time | Date | Time | |
| 3 | 5/3/19 | 0641 | --- | --- | Turbine runner replacement and stator rewind |

Comments: None.

Adult Fish Passage Facility

Ice Harbor fish facility staff inspected the adult fishways on March 10, 11, and 12.

Fish Ladders:

| Yes | No | Location | Criteria | Measurements |
|-----|----|---|-----------------------------|--------------|
| X | | North Ladder Exit Differential | Head \leq 0.3' | |
| X | | North Ladder Picketed Lead Differential | Head \leq 0.3' | |
| X | | North Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |
| X | | South Ladder Exit Differential | Head \leq 0.3' | |
| X | | South Ladder Picketed Lead Differential | Head \leq 0.3' | |
| X | | South Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |

Fishway Entrances and Collection Channel:

| Yes | No | Sill | Location | Criteria | Measurements |
|-----|----|------|--|------------------------|--------------|
| X | | | South Shore Entrance (SFE-1) Weir Depth | \geq 8.0' or on sill | |
| X | | | South Shore Channel/Tailwater Differential | 1.0' – 2.0' | |
| X | | | South Shore Channel Velocity | 1.5 – 4.0 fps | |
| | X | | North Powerhouse Entrance (NFE-2) Weir Depth | \geq 8.0' or on sill | 7.9' |
| X | | | North Powerhouse Entrance Channel/Tailwater Differential | 1.0' – 2.0' | |
| X | | | North Shore Entrance (NEW-1) Weir Depth | \geq 8.0' or on sill | |
| X | | | North Shore Channel/Tailwater Differential | 1.0' – 2.0' | |

Comments: The north powerhouse entrance weir depth was slightly below criteria on the March 10 fishway inspection. By the time the weir elevation was read from the control room PLC, the weir may have automatically adjusted upwards in response to an increase in the tailwater elevation, leading to a weir depth of 7.9' when compared against the original tailwater reading. The new mechanical dial on the NFE-2 weir selsyn motor that shows the weir elevation could not be calibrated during the winter maintenance period, because the dial does not have the correct gear ratio for the application.

Auxiliary Water Supply (AWS) System:

| Operating Satisfactory | Standby | Out of Service | Auxiliary Water Supply System (AWS) |
|------------------------|---------|----------------|---------------------------------------|
| 6 pumps | 1 pump | 1 pump | Status of the 8 South Shore AWS Pumps |
| 2 pumps | 1 pump | | Status of the 3 North Shore AWS Pumps |

Comments: South shore AWS pump #1 is out of service because of worn bearings in the motor. Work is underway to replace the bearings.

Juvenile Fish Passage Facility

Forebay Debris/Gatewell Debris/Oil:

| Yes | No | NA | Item | Comments |
|-----|----|----|---|-------------------------------|
| X | | | Forebay debris load acceptable? (amount) | Average of 153 square yards |
| | | X | Gatewell drawdown measured this week? | |
| | | X | Gatewell drawdown acceptable | |
| X | | | Any debris seen in gatewells (% coverage) | STSs blocking view into slots |
| | X | | Any oil seen in gatewells? | |

Comments: None.

STSs/VBSs:

| Yes | No | NA | Item |
|-----|----|----|--|
| | X | | STSs deployed in all slots and in service? |
| | | X | STSs in continuous-run mode (Note: if not, then STSs are in cycle-run mode)? |
| | | X | STSs inspected this week? |
| | | X | STSs inspection results acceptable? |
| | | X | VBSs differentials checked this week? |
| | | X | VBSs differentials acceptable? |

Comments: The STSs are removed for annual maintenance.

Orifices, Collection Channel, Dewatering Structure, and Flume:

| Yes | No | NA | Item | Number open and in service |
|-----|----|----|--|----------------------------|
| | | X | Orifices operating satisfactory? | 0 |
| | | X | Dewaterer and cleaning systems operating satisfactory? | |

Comments: The juvenile fish channel is unwatered for annual maintenance.

Juvenile Fish Facility: The fish facility is unwatered for annual maintenance.

Fish Sampling: Sampling begins on April 2.

Removable Spillway Weir (RSW): Voluntary spill for fish passage begins on April 3.

River Conditions

River conditions at Ice Harbor Dam.

| Daily Average River Flow (kcfs) | | Daily Average Spill (kcfs) | | Water Temperature* (°F) | | Water Clarity (Secchi disk - feet) | |
|---------------------------------|------|----------------------------|-----|-------------------------|-----|------------------------------------|-----|
| High | Low | High | Low | High | Low | High | Low |
| 35.5 | 29.4 | 0 | 0 | 42 | 42 | 2.6 | 1.2 |

*Unit 1 scroll case temperature.

Other

Inline Cooling Water Strainers: Unit 1, 2, 4, 5, and 6 turbine cooling water strainer inspections took place on March 5. A total of approximately 2,765 dead juvenile lamprey and 24 live juvenile lamprey were recovered. The live lamprey were found in the strainers in fair to poor condition, and were released into the tailrace.

Avian Activity: There were very few piscivorous birds seen around the project.

Invasive Species: No exotic species that are new to the area have been found.

Siberian Prawn: Siberian prawns collected in the sample at the Juvenile Fish Facility will be humanely euthanized by EAS, frozen and properly disposed of in a landfill.

Fish Rescue/Salvage: Unwatering activities that involved fish rescue did not occur this week.

Research: No on-site research is occurring at this time.

Project: Lower Monumental

Biologists: Chuck Barnes and Raymond Addis

Dates: March 6 - 12, 2020

Turbine Operation

| Yes | No | Turbine Unit Status | | |
|-----|----|---|-------------|-------------|
| | X | All 6 turbine units available for service (see table & comments below for details). | Hard | Soft |
| X | | Available turbines operated within 1% peak efficiency? Constraint in effect. | | X |

Lower Monumental Unit Outages (OOS) and Return to Service (RTS)

| Unit | OOS | | RTS | | Outage Description |
|--------|------------|------|-----------|-------|--------------------------|
| | Date | Time | Date | Time | |
| Unit 1 | 12/18/2019 | 0830 | 3/10/2020 | 13:00 | Warranty Work - Seals |
| Unit 2 | 7/15/2019 | 0720 | 7/17/2020 | ERTS | Annual, Draft Tube Liner |

Comments: None.

Adult Fish Passage Facility

The adult fishways were inspected by Corps biologists on March 9, 11 and 12.

Fish Ladder:

| Yes | No | Location | Criteria | Measurements |
|-----|----|---|-----------------------------|--------------|
| X | | North Ladder Exit Differential | Head \leq 0.5' | |
| X | | North Ladder Picketed Lead Differential | Head \leq 0.4' | |
| X | | North Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |
| X | | South Ladder Exit Differential | Head \leq 0.5' | |
| X | | South Ladder Picketed Lead Differential | Head \leq 0.3' | |
| X | | South Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |

Comments: None.

Fishway Entrances and Collection Channel:

| Yes | No | Sill | Location | Criteria | Measurements |
|-----|----|------|--|------------------------|--------------|
| X | | | North Shore Entrance (NSE-1) Weir Depth | \geq 8.0' or on sill | |
| X | | | North Shore Entrance (NSE-2) Weir Depth | \geq 8.0' or on sill | |
| X | | | North Shore Channel/Tailwater Differential | 1.0'-2.0' | |
| | | X | South Powerhouse Entrance (SPE-1) Weir Depth | \geq 8.0' or on sill | |
| | | X | South Powerhouse Entrance (SPE-2) Weir Depth | \geq 8.0' or on sill | |
| X | | | South Powerhouse Entrance Channel/Tailwater Differential | 1.0'-2.0' | |
| | X | X | South Shore Entrance (SSE-1) Weir Depth | \geq 8.0' | |
| X | | | South Shore Entrance (SSE-2) Weir Depth | \geq 6.0' | |
| X | | | South Shore Channel/Tailwater Differential | 1.0' - 2.0' | |

Comments: South Powerhouse Entrance weir (SPE-1) was on sill during all inspections with readings of 7.0, 7.1 and 6.6 feet respectively.

South Powerhouse Entrance weir (SPE-2) was on sill during all inspections with readings of 7.0, 7.1 and 6.6 feet respectively.

South Shore Entrance weir (SSE-1) was out of criteria on the March 9 inspection with a reading of 7.6 feet. The powerhouse operator placed the weir at sill. It remained on sill during the March 11 and 12 inspections with readings of 8.2 and 7.7 feet respectively.

Auxiliary Water Supply System:

| Operating Satisfactory | Standby | Out of Service | Auxiliary Water Supply System (AWS) |
|------------------------|---------|----------------|-------------------------------------|
| Yes | | | AWS Fish Pump 1 |
| Yes | | | AWS Fish Pump 2 |
| Yes | | | AWS Fish Pump 3 |

Comments: None.

Juvenile Fish Passage Facility

Forebay Debris/Gatewell Debris/Oil:

| Yes | No | NA | Item | Comments |
|-----|----|----|---|----------------------|
| X | | | Forebay debris load acceptable? (amount) | 103 yds ² |
| | | X | Gatewell drawdown measured this week? | |
| | | X | Gatewell drawdown acceptable | |
| | | X | Any debris seen in gatewells (% coverage) | |
| | | X | Any oil seen in gatewells? | |

STSs/VBSs:

| Yes | No | NA | Item |
|-----|----|----|--|
| | X | | STSs deployed in all slots and in service? |
| | | X | STSs in continuous-run mode (Note: if not, then STSs are in cycle-run mode)? |
| | X | | STSs inspected this week? |
| | | X | STSs inspection results acceptable? |
| | | X | VBSs differentials checked this week? |
| | | X | VBSs differentials acceptable? |

Comments: STS's are not yet deployed for the 2020 season.

Orifices, Collection Channel, Dewatering Structure, and Flume:

| Yes | No | NA | Item | Number open and in service |
|-----|----|----|--|----------------------------|
| | | X | Orifices operating satisfactory? | 0 |
| | | X | Dewaterer and cleaning systems operating satisfactory? | |

Comments: Orifices are closed and Dewaterer is OOS for winter maintenance.

Collection Facility: Fish collection is scheduled to begin on April 1.

Transport Summary: No transport at this time.

Spillway Weir: RSW scheduled to go into service at 0001 on April 3.

River Conditions

River conditions at Lower Monumental Dam.

| Daily Average River Flow (kcfs) | | Daily Average Spill (kcfs) | | Water Temperature (°F)* | | Water Clarity (Secchi disk - feet) | |
|---------------------------------|------|----------------------------|-----|-------------------------|------|------------------------------------|-----|
| High | Low | High | Low | High | Low | High | Low |
| 35.2 | 29.2 | 0.0 | 0.0 | 43.8 | 41.4 | 3.6 | 3.0 |

*March 3 temperature was taken from the South Power House collection channel. All other were Scrollcase temperatures.

Other

Inline Cooling Water Strainers: Cooling water strainers were inspected on March 4. Five live juvenile lamprey were salvaged. Mortalities included 346 juvenile lamprey.

Avian Activity: Highest counts of foraging piscivorous birds in tailrace at Lower Monumental Dam are below.

| Date | Time | Gulls | Cormorants | Terns | Grebes | Pelicans |
|------------|------|-------|------------|-------|--------|----------|
| March 6-12 | NA | 0 | 0 | 0 | 0 | 0 |

Invasive Species: No zebra or quagga mussels were observed during monitoring station inspections on March 3.

Fish Rescue/Salvage: No Fish Rescue/Salvage took place during this reporting period.

Research: No research is occurring at this time.

Project: Little Goose

Biologists: Scott St. John and Richard Weis

Dates: March 6 – March 12, 2020

Turbine Operation

| Yes | No | Turbine Unit Status | Hard | Soft |
|-----|----|---|------|------|
| | X | All 6 turbine units available for service (see table & comments below for details). | | |
| X | | Available turbines operated within 1% peak efficiency? Constraint in effect. | | X |

Little Goose Unit Outages (OOS) and Return to Service (RTS)

| Unit | OOS | | RTS | | Outage Description |
|------|----------|-------|------------|-------|--|
| | Date | Time | Date | Time | |
| 5 | 04/14/17 | 14:11 | 03/31/2021 | 17:00 | Spider and upper guide bearing repair. |

Comments: None.

Adult Fish Passage Facility

Little Goose fish facility staff inspected the adult Fishway on March 09, 10 and 12.

Fish Ladder:

| Yes | No | NA | Location | Criteria | Measurements |
|-----|----|----|---|-----------------------------|--------------|
| X | | | Fish Ladder Exit Differential | Head \leq 0.5' | |
| X | | | Fish Ladder Picketed Lead Differential | Head \leq 0.3' | |
| X | | | Fish Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |
| | | X | Fish Ladder Cooling Water Pumps in Service | | |
| | | X | Fish Ladder Exit Cooling Water Pumps Operating Satisfactorily | | |

Fishway Entrances and Collection Channel:

| Yes | No | Sill | Location | Criteria | Measurements |
|-----|----|------|--|------------------------|---------------|
| X | | | South Shore Entrance (SSE-1) Weir Depth | \geq 8.0' | |
| X | | | South Shore Entrance (SSE-2) Weir Depth | \geq 8.0' | |
| X | | | South Shore Channel/Tailwater Differential | 1.0' – 2.0' | |
| | | X | North Powerhouse Entrance (NPE-1) Weir Depth | \geq 7.0' or on sill | |
| | | X | North Powerhouse Entrance (NPE-2) Weir Depth | \geq 7.0' or on sill | |
| X | | | North Powerhouse Entrance Channel/Tailwater Differential | 1.0'–2.0' | |
| X | | | North Shore Entrance (NSE-1) Weir Depth | \geq 6.0' or on sill | |
| | X | | North Shore Entrance (NSE-2) Weir Depth | \geq 6.0' or on sill | 5.8 |
| | X | | North Shore Channel/Tailwater Differential | 1.0'–2.0' | 0.8, 0.8, 0.9 |
| X | | | Collection Channel Surface Velocity | 1.5 – 4.0 fps | |

Comments: The NSE-2 weir depth was found out of criteria on March 12. Upon inspection, the fish control system computer had a faulty I/O module for the NSE weirs and is currently being repaired. Therefore, NSE-2 weir depth appeared to be within criteria. The NSE channel/tailwater differential was found out of criteria on all inspections this report period. Once all AWS pumps are in service and/or the juvenile bypass is returned to service, velocity measurements should meet criteria.

Auxiliary Water Supply System:

| Operating Satisfactory | Standby | Out of Service | Auxiliary Water Supply System (AWS) |
|------------------------|---------|----------------|-------------------------------------|
| | | X | AWS Fish Pump 1 |
| X | | | AWS Fish Pump 2 |
| X | | | AWS Fish Pump 3 |

Comments: Fish pumps were returned to service on February 27. Shortly after the pumps were started, maintenance staff noticed that the oiling system in the gearbox of fish pump 1 was not working correctly. Fish pump 1 was taken out of service and is currently being repaired.

Juvenile Fish Passage Facility

Forebay Debris/Gatewell Debris/Oil:

| Yes | No | NA | Item | Comment |
|-----|----|----|---|---------|
| X | | | Forebay debris load acceptable? (amount) | |
| | | X | Gatewell drawdown measured this week? | |
| | | X | Gatewell drawdown acceptable | |
| | | X | Any debris seen in gatewells (% coverage) | |
| | X | | Any oil seen in gatewells? | |

Comments: There is approximately 11,225 square feet of floating woody debris currently inside the trash shear boom in the forebay.

ESBS/VBS:

| Yes | No | NA | Item |
|-----|----|----|---|
| | | X | ESBSs deployed in all slots and in service? |
| | | X | ESBSs inspected this week? |
| | | X | ESBSs inspection results acceptable? |
| | | X | VBSs differentials checked this week? |
| | | X | VBSs differentials acceptable? |
| | | X | VBSs inspected this week? |

Comments: ESBS's are scheduled to be installed the week of March 16.

Orifices, Collection Channel, Dewatering Structure, and Flume:

| Yes | No | NA | Item | Number open and in service |
|-----|----|----|--|----------------------------|
| X | | | Orifices operating satisfactory? | 18 |
| X | | | Dewaterer and cleaning systems operating satisfactory? | |

Comments: The juvenile bypass system was returned to service on March 12 and is operating in primary bypass.

Collection Facility: The juvenile collection facility is currently dewatered for winter maintenance.

Transport Summary: Fish transportation is scheduled to begin in April.

Spillway Weir: Spring spill operations will begin on April 03.

River Conditions

River conditions at Little Goose Dam.

| Daily Average River Flow (kcfs) | | Daily Average Spill (kcfs) | | Water Temperature* (°F) | | Water Clarity (Secchi disk - feet) | |
|---------------------------------|------|----------------------------|-----|-------------------------|------|------------------------------------|-----|
| High | Low | High | Low | High | Low | High | Low |
| 35.5 | 28.5 | 0.0 | 0.0 | 42.5 | 42.1 | 5.6 | 4.6 |

*Ladder temperature.

Other

Inline Cooling Water Strainers: Inline cooling strainers are being inspected and results submitted to district operations every other week for FPOM distribution.

Avian Activity: Daily piscivorous bird counts at Little Goose Dam will begin on April 01.

Invasive Species: No invasive species have been observed on the mussel station.

Siberian Prawn: Juvenile fish collection begins on April 01. Siberian prawns collected in the sample at the Juvenile Fish Facility are humanely euthanized by Oregon Department of Fish and Wildlife and EAS, frozen and properly disposed of in a landfill. No sampling is being conducted at this time thus no Siberian prawns were collected this reporting period.

Gas Bubble Trauma (GBT): GBT monitoring is not being conducted at this time.

Fish Rescue/Salvage: None.

Research: None.

Project: Lower Granite

Biologists: Elizabeth Holdren and David Miller

Dates: March 6-12, 2020

Turbine Operation

| Yes | No | Turbine Unit Status | Hard | Soft |
|-----|----|---|------|------|
| | X | All 6 turbine units available for service (see table & comments below for details). | | |
| | | Available turbines operated within 1% peak efficiency? Constraint in effect. | | X |

Lower Granite Unit Outages (OOS) and Return to Service (RTS)

| Unit | OOS | | RTS | | Outage Description |
|------|------------|------|------|------|--------------------|
| | Date | Time | Date | Time | |
| 2 | Nov 4 2019 | | | | Overhaul |

Comments: None.

Adult Fish Passage Facility

The adult fishway was watered up February 10 with gravity flow. AWS pumps 1 and 2 were returned to service at 1530 hours February 11. Lower Granite and EAS/Anchor QEA staff inspected the adult fishway on March 6, 7, 8, 11, and 12.

Fish Ladder:

| Yes | No | NA | Location | Criteria | Comments |
|-----|----|----|--|-----------------------------|----------|
| X | | | Fish Ladder Exit Differential | Head \leq 0.5' | |
| X | | | Fish Ladder Picketed Lead Differential | Head \leq 0.3' | |
| X | | | Fish Ladder Depth over Weirs | Head over weir 1.0' to 1.3' | |
| | | X | Fish Ladder Cooling Water Pumps in Service | | |
| | | X | Fish Ladder Cooling Water Pumps Operating Satisfactorily | | |

Comments: None.

Fish Ladder Entrances and Collection Channel:

| Yes | No | Sill | Location | Criteria | Comments |
|-----|----|------|--|------------------------|-------------------------|
| X | | | South Shore Entrance (SSE-1) Weir Depth | \geq 8.0' | |
| | X | | South Shore Entrance (SSE-2) Weir Depth | \geq 8.0' | 7.7 |
| X | | | South Shore Channel/Tailwater Differential | 1.0' – 2.0' | |
| | X | | North Powerhouse Entrance (NPE-1) Weir Depth | \geq 8.0' or on sill | 7.9, 7.9 |
| | X | | North Powerhouse Entrance (NPE-2) Weir Depth | \geq 8.0' or on sill | 7.6, 7.9, 7.4 |
| X | | | North Powerhouse Entrance Channel/Tailwater Differential | 1.0'–2.0' | |
| | X | | North Shore Entrance (NSE-1) Weir Depth | \geq 7.0' or on sill | 6.9, 6.8 |
| | | | North Shore Entrance (NSE-2) Weir Depth | \geq 7.0' or on sill | Closed |
| X | | | North Shore Channel/Tailwater Differential | 1.0'–2.0' | |
| | X | | Collection Channel Surface Velocity | 1.5 – 4.0 fps | 1.1, 1.1, 1.1, 1.0, 0.9 |

Comments: All depth over weir out of criteria readings were likely related to fine tuning of the fish ladder control system. FOGs 1, 4, 7, and 10 are in operation. FOGs 4 and 7 were returned to operation to eliminate one of the variables impacting the fish ladder control system. Once the problems with fish ladder control system and local staff gauge reading inconsistencies are resolved FOG operation will be revisited.

Auxiliary Water Supply System:

| Operating Satisfactorily | Standby | Out of Service | Auxiliary Water Supply (AWS) |
|--------------------------|---------|-------------------|------------------------------|
| Yes | | | AWS Fish Pump 1 |
| Yes | | | AWS Fish Pump 2 |
| No | | OOS guide bearing | AWS Fish Pump 3 |

Comments: None.

Juvenile Fish Passage Facility

The juvenile bypass system was watered up on February 20 and sent to primary bypass.

Forebay Debris/Gatewell Debris/Oil:

| Yes | No | NA | Item | Comments |
|-----|----|----|--|----------|
| X | | | Forebay debris load acceptable? (amount) | |
| X | | | Trash rack differentials measured this week? | |
| X | | | Trash rack differentials acceptable | |
| | X | | Any debris seen in gatewells (% coverage) | |
| | X | | Any oil seen in gatewells? | |

Comments: Unit trash racks were raked February 18 and 19.

ESBSs/VBSs:

| Yes | No | NA | Item |
|-----|----|----|---|
| X | | | ESBSs deployed in all slots and in service? |
| | X | | ESBSs inspected this week? |
| | | X | ESBSs inspection results acceptable? |
| X | | | VBSs differentials checked this week? |
| X | | | VBSs differentials acceptable? |

Comments: ESBS were installed in unit 2 gatewell slots prior to the unit being returned to service March 13.

Orifices, Collection Channel, Dewatering Structure, Bypass Pipe:

| Yes | No | NA | Item | Number open and in service |
|-----|----|----|--|----------------------------|
| X | | | Orifices operating satisfactory? | 24 |
| X | | | Dewaterer and cleaning systems operating satisfactory? | |

Comments: Forebay elevation is operating between 733-734 feet to facilitate installation of a fishing dock in Clarkston, WA. Orifice configuration included all 14" orifices open along with the 10" orifices for units 5 and 6.

Collection Facility: The sample rate remained 100% for the week. A total of 70 juvenile salmonids were collected March 6-12.

Transport Summary: No transport at this time.

Spillway Weir: The spillway 1 PIT tag detection contract was completed in February. Spring spill and RSW operation will begin at 0001 hours April 3.

River Conditions

River conditions at Lower Granite Dam.

| Daily Average River Flow (kcfs) | | Daily Average Spill (kcfs) | | Water Temperature* (°F) | | Water Clarity (Secchi disk - feet) | |
|---------------------------------|------|----------------------------|-----|-------------------------|------|------------------------------------|-----|
| High | Low | High | Low | High | Low | High | Low |
| 35.8 | 31.9 | 0.0 | 0.0 | 42.5 | 41.0 | 5+ | 4.5 |

*Cooling water intake temperature.

Other

Inline Cooling Water Strainers: Unit cooling strainer inspections were conducted on February 27.

Invasive Species: No zebra/quagga muscles were detected on the trap substrate. There were 6 Siberian prawns collected in the sample and euthanized for disposal.

Avian Activity: Biologist daily piscivorous bird counts at Lower Granite Dam.

| Date | Time | Gulls | Cormorants | Caspian Terns | Pelicans |
|----------|------|-------|------------|---------------|----------|
| March 6 | 1240 | 7 | 0 | 0 | 0 |
| March 7 | 1130 | 7 | 1 | 0 | 0 |
| March 8 | 0920 | 16 | 1 | 0 | 0 |
| March 9 | 1315 | 11 | 3 | 0 | 0 |
| March 10 | 0948 | 5 | 1 | 0 | 0 |
| March 11 | 0954 | 4 | 0 | 0 | 0 |
| March 12 | 1245 | 0 | 2 | 0 | 0 |

Gas Bubble Trauma (GBT) Monitoring: N/A

Adult Fish Trap Operations: The adult trap was watered up at 1200 hours March 2 started sampling at a 28% (20% /week) sample rate. Collection for sampling will be conducted Monday through Friday until broodstock collection starts August 18.

Fish Rescue/Salvage: N/A

Research:

Idaho Fish and Game (IDFG) Genetic Stock Identification

Fish collected as part of the Lower Granite juvenile condition sample are used to enumerate and characterize age composition and genetic stock profiles of naturally producing yearling chinook and juvenile steelhead. IDFG will sample Monday through Friday through mid-June with a goal of collecting 2,000-5,000 yearling chinook and juvenile steelhead genetic samples.

National Marine Fisheries Service (NMFS) PIT tagging of Adult Wild Chinook and Adult Steelhead for ISEMP-Related Dispersal Monitoring

The goal of this project is to PIT tag up to 4000 unclipped adult Chinook and 4000 unclipped adult steelhead collected in the adult trap daily sample for dispersal monitoring.

National Marine Fisheries Service (NMFS) Ancillary Adult Passage Monitoring:

Fish that were PIT as juveniles at LWG are monitored as returning adults through the river and LWG facility. For each returning adult the following is estimated; 1) passage time between sets of detection PIT tag coils, 2) whether the fish was handled at the adult trap, 3) duration the fish was held at the adult trap, 4) overall passage time from ladder entrance to exit, 5) whether the turnpool gate was open or closed during passage. This will be the last year of this evaluation.

Sampling of Steelhead, Chinook salmon, and Sockeye salmon by the Idaho Department of Fish and Game (IDFG) and NOAA Fisheries for Biological data collection.

Upriver migrating steelhead, spring/summer Chinook salmon, and sockeye salmon are collected from the adult trap beginning April 4 through December 15. The goal is to collect 5-20% of adult steelhead, spring/summer Chinook salmon, and sockeye salmon ascending the ladder April 4-December 15. Data collection includes fish scales, genetics tissue, sex and length, wild/hatchery composition, and non-adipose clipped hatchery fish assessment. All natural origin adult steelhead and spring/summer Chinook salmon trapped will be PIT tagged to estimate headwater tributary escapement. Sockeye salmon may be PIT tagged in the future to estimate metrics regarding conversion rates. Some steelhead and spring/summer Chinook salmon may be radio-tagged or spaghetti-tagged. This information on adult fish forms the basis for status information used in several forums including BiOp-RPA identified needs.

PIT Tagging and Genetic Sample Collection from Bull Trout for USFWS:

Bull trout will be collected as part of the normal adult trap daily sample and using the adult SbyC system to recapture previously PIT tagged fish. Untagged bull trout will be PIT tagged, fin clipped for genetic analysis, and have morphometric data collected including weight and length etc. Fin clips will be sent to USFWS to determine the fish's origin. Previously PIT tagged bull trout will only have morphometric data collected. All fish will be released back into the adult fish ladder.