

**OFFICIAL COORDINATION REQUEST FOR
NON-ROUTINE OPERATIONS AND MAINTENANCE**

COORDINATION TITLE- 21CGR03 Cougar Adult Fish Facility Generator Auto Transfer Switch install

COORDINATION DATE- 05 May 2021

PROJECT- Cougar Dam

RESPONSE DATE- 17 May 2021

Description of the problem

The automatic transfer switch on the emergency generator failed. This switch automatically transfers electricity to the pumps during a loss of power. Crews are planning to replace the faulty part with a new transfer switch.

Type of outage/change required

Fish facility outage

Impact on facility operation Facility will not be in operation while repairs are being made

Dates of impacts/repairs

18 May

Length of time for repairs

24 hours

Expected impacts on fish

Minimal impacts expected for fish.

Comments from agencies

No comments

Final results

Work completed as planned