

Project Data - FCRPS (Federal Columbia River Power System)

Project	Unit Number	Number of units	Sustained Capacity (MW)	Total Plant (MW)	Normal Full (ft)	Normal Minimum (ft)	Minimum Discharge (kcfs)	Hydraulic Capacity (kcfs)	Ramp Rates
Albeni Falls	1 - 3	3	16.3	49.0	2062.5	2051	4	33	Normal 60 min limit 5 kcfs/hr Max 60 minute increase or decrease 1 ft/hr Max daily increase 10 kcfs/day Max daily reduction below 50 kcfs 10 kcfs/day Min daily reduction 50 to 75 kcfs 2 ft/day Min daily reduction above 75 1 ft/day
Bonneville	1 - 10	10	60.0	1,195.2	76.5	71.5	***80 instantaneous 100 daily average	136	
	11 - 18	8	76.5					152	
	2-F	2	13.1	26.2					
Chief Joseph	1 - 4	4	88.3	2,614.0	956	950	Min daily 35	219	
	5 - 14	10	88.3						
	15 - 16	2	88.3						
	17 - 27	11	109.0						
Dworshak	1 - 2	2	103.0	465.0	1600	1445	1	10.5	At peck 1 ft/hr At peck 40% of previous weekly average outflow
	3	1	259.0						
Grand Coulee	1 - 18	18	125.0	7,079.0	1290	1208		280	Max. forebay (drawdown) change 1.5 ft/day, under most conditions
	19 - 21	3	690.0						
	22 - 24	3	805.0						
	3-S	3	10.0						
	2-PG	2	50.0						
	4-PG	4	53.5						
Hungry Horse	1 - 4	4	107.0	428.0	3560	3336	0.4	8.9	*
Ice Harbor	1 - 3	3	103.0	693.0	440	437	Dec – Feb 0 Mar – Jul 9.5 Aug – Nov 7.5	106	Max. rate of change 20 kcfs/hr
	4 - 6	3	128.0						
John Day	1 - 16	16	155.0	2,480.0	265	262.5 April - Sept Operate within lowest 1.5' range to allow for irrigation	Dec – Feb 12.5 Mar – Nov 50 kcfs	322	Max. rate of change 200 kcfs/hr

Project	Unit Number	Number of units	Sustained Capacity (MW)	Total Plant (MW)	Normal Full (ft)	Normal Minimum (ft)	Minimum Discharge (kcfs)	Hydraulic Capacity (kcfs)	Ramp Rates
Libby	1 - 5	5	121.0	605.0	2459	2287	2 instantaneous 3 daily average 4 preferred	24.1	*
Little Goose	1 - 3	3	155.0	930.0	638	*633	Dec – Feb 0 Mar – Nov 11.5	130	Max. rate of change 70 kcfs/hr
	4 - 6	3	155.0						
Lower Granite	1 - 3	3	155.0	930.0	738	*733	Dec – Feb 0 Mar – Nov 11.5	130	Max. rate of change 70 kcfs/hr
	4 - 6	3	155.0						
Lower Monumental	1 - 3	3	155.0	930.0	540	*537	Dec – Feb 0 Mar – Nov 11.5	130	Max. rate of change 70 kcfs/hr
	4 - 6	3	155.0						
McNary	1 - 14	14	80.0	1,120.0	340	335	Dec – Feb 12.5 Mar – Nov 50	232	Max. rate of change 150 kcfs/hr
The Dalles	1 - 14	14	90.0	2,052.0	160	155	Dec – Feb 12.5 Mar – Nov 50	375	Max. rate of change 150 kcfs/hr
	15 - 22	8	99.0						
	2-F	2	14.0	28.0					

* - Project ramp rates specified in BiOps (see Water Management Plan)

** - When average weekly inflow is below 125 kcfs, the minimum instantaneous outflow limit is 70 kcfs and the minimum daily average discharge limit is 80% of the weekly average inflow.

*** - For Lower Snake River Dams: subject to minimum operating pool (MOP) Apr – Aug. See Water Management Plan.